



## ADDENDUM | No. 1

<b>PROJECT</b>	Hartford Beach State Park Electrical Upgrades		
<b>BID DATE</b>	3:30 PM	CT	05/20/25
<b>BID LOCATION</b>	Foss Building 523 East Capitol Avenue Pierre, SD 57501-3182		
<b>ISSUE DATE</b>	05/13/2025		
<b>NOTICE</b>	Failure to acknowledge all addenda in the BID may cause rejection of the BID. See Instructions to Bidders.		

### SCOPE OF THIS ADDENDUM

The following becomes a part of the original project manual and drawings, taking precedence over the items that may conflict. The bidder shall note receipt and make acknowledgment of the Addendum on his/her bid form, incorporating its provision in his/her bid.

- See attached.

Project Manual and Drawing inquiries regarding the work should be directed to:

### CONTACT PERSON(S)

Banner Associates, Inc.	Tel 1-605-692-6342   Toll Free 1-855-323-6342   Fax 1-605-692-5714	
-------------------------	--	--

Rich Uckert, PE	Civil/Construction Administration Project Manager	richu@bannerassociates.com
-----------------	---	----------------------------

West Plains Engineering	Tel 1-605-306-8048
-------------------------	--------------------

Parker Amundson	Electrical Designer	Parker.Amundson@westplainsengineering.com
-----------------	---------------------	---

### ATTACHMENTS

1. Mechanical/Electrical Addendum No. 1

**Date:** May 13, 2025

**Project:** Hartford Beach Electrical Upgrades

**To:** All Bidders

**Project #:** BS23010

**From:** Parker Amundson

**Project Location:** Roberts County, SD

**Addendum Number:** 1

**To:** All prime contract bidders and all others to whom Drawings and Specifications have been issued by the Engineer. Acknowledge receipt of the Addendum by inserting its number and date on the Bid Form. Failure to do so may subject bidder to disqualification. This Addendum forms a part of the Contract Documents. It modifies them as follows:

**Product Approvals**

The manufacturers and products, which are listed in the following texts, are approved for bidding. Final acceptance is contingent upon receipt and approval of final shop drawings. Manufacturer shall conform to all warranties, performances, size, etc., as the item specified. The burden of proof of the merit of the proposed substitution is upon the proposer. Those items not specifically listed by addendum shall not be approved for bidding.

<u>Specification/Sheet</u>	<u>Description</u>	<u>Manufacturer</u>
Sheet E1009	RV Camper Site Power Pedestal	Milbank

**Clarifications**

1. MHF cable would be an acceptable means to feed the electrical camper pedestals on this site.



END OF DOCUMENT – PA